



Certificate of Compliance

Certificate: 70171764

Master Contract: 213842

Project: 70171764

Date Issued: 2018-02-21

Issued to: UWT GmbH
Westendstrasse 5
Betzigau, 87488
GERMANY
Attention:

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



Issued by: Sam Zaffino
Sam Zaffino

PRODUCTS

CLASS - C225205 - PROCESS CONTROL EQUIPMENT

CLASS - C225285 - PROCESS CONTROL EQUIPMENT-Certified to US Standards

Capacitance Level Switches, Capanivo Series CN8000, Type CN8100 and RFnivo Series RF8000, Types RF8100 and RF8200, Type 4/NEMA 4/IP68 enclosure, conduit connected, Rated Input 12 to 250Vac/dc, 2W max; Alarm contacts rated 250Vac, 8A or 30Vdc, 5A and 30Vdc, 82mA; Ambient -40 to 85°C; Pollution Degree 4, Installation Category II.

APPLICABLE REQUIREMENTS

CAN/CSA-C22.2 No. 61010-1-04 - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements

ISA S82.02.01 2nd (IEC 61010-1 Mod) - Safety Standards for Electrical and Electronic Test, Measuring, Controlling and Related Equipment - General Requirements.

UL 61010-1 2nd - Safety Requirements for Electrical Equipment for Measurement, Control, and Laboratory Use, Part 1: General Requirements



Supplement to Certificate of Compliance

Certificate: 70171764

Master Contract: 213842

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
70171764	2018-02-21	Transfer of report -1956162 to UWT with update on model nos., drawings